

**Subject : - Response / clarification of Pre-Bid queries raised**

**Name of contract: Comprehensive Operation & Maintenance Contract for two Sewage Treatment Plants (STP-1 and STP-2) at IIM Indore.**

**Ref. NIT No. - NIT / IIMI/Estate/06/2019/06, File No. 123**

<b>Sl. No.</b>	<b>Query</b>	<b>Response/ clarification by IIM Indore</b>
1	Kindly clarify the Plant Capacity of Both the STP Plants, as nowhere mentioned in NIT.	The capacity of STP-1 is 360 KLD & of STP-2 is 100 KLD.
2	Kindy clarify regarding the GST will be added extra or to be deducted from the tendered value. As mentioned in Clause 29, Page no. 7 (i) which is extra and will be reimbursed. Pls clarify.	You have to quote your rate excluding GST.
3	Pls clarify regarding the Sample testing reqtired or not. If required pls indicate whether to be done quarterly/Monthaly.	Sample testing is to be done every fortnightly as per Clause no. 20, Page no. 25
4	As the tender has been invited for comprehensive maintenance, kindly clarify regarding painting work and civil maintenance is included or not.	Painting work & civil works of pipe lines, plant & machinery as a part of comprehensive maintenance is to be done by the contractor .
5	Regarding the Minimum, wages, the applicable wages will be of whether central or MP Government. Pls clarify.	Minimum Wages will be applicable of Central Govt.

(Executive Engineer Civil)  
IIM Indore