

Ref. No.: IIMI/Project/2026/529/ 3033

July 16, 2026

Corrigendum 1: Response to Prebid Queries

Tender Reference No. : IIMI/Project/07/2026/180 File no. 529

Tender ID : 2026_IIMID_916923_1

Tender Title : “Supply, Installation, Testing and Commissioning of 750 KVA DG set and 2500 KVA 11/0.433 KV Distribution Transformer for utility-2 at IIM Indore.”

Response to Prebid Queries:

S. No.	Clause No. / Page No. of NIT	Query	Response to Prebid queries
1	D.a).1.Note (Page No. 12)	Can multiple smaller capacity DG / Transformer clubbed together resulting into matching the capacity mentioned under similar work be considered or not?	No. The capacity mentioned is minimum capacity for a single DG of 750 KVA and in case of Transformer also it is single 2500 KVA.

Note: All other NIT conditions remains unchanged.


Chief Officer Engineering
IIM Indore